

---

**From:** Keith M. Homza (Generation - 3) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=KEITH20]  
**Sent:** 4/28/2015 7:02:39 AM  
**To:** Jeffrey R Marcell (Generation - 3) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Jeff136]  
**Subject:** RE: E Pond Ash Removal

Awesome ! I forwarded the e-mail to Dana.

**From:** Jeffrey R Marcell (Generation - 3)  
**Sent:** Monday, April 27, 2015 8:22 PM  
**To:** Keith M. Homza (Generation - 3)  
**Cc:** Barbara Monteiro (Generation - 3)  
**Subject:** FW: E Pond Ash Removal

FYI

Worked with Reuben this afternoon to place a submersible pump at E Pond discharge, he had it in place and functional by 1800. He put it in the concrete basin below the discharge pipe before it enters the "beaver pond".

Crofton will fix the concrete leak internal to the weir after C Pond repairs are completed, expected start is Monday or Tuesday unless legal wants them to work the weekend.

Jeff Marcell

Environmental Supervisor

Possum Point Power Station

Ladysmith & Remington CT Sites

703-441-3813 (phone)

8-795-3813 (tie)

703-441-3897 (fax)

**From:** Leonard C Pope (Generation - 34)

**Sent:** Monday, April 27, 2015 6:54 PM

**To:** Michael A Glagola (Generation - 34); Bob Jackson (Generation - 34); Jeffrey C Heffelman (Generation - 3); Jeffrey R Marcell (Generation - 3); Donald Fines (Generation - 34)

**Cc:** Leonard C Pope (Generation - 34)

**Subject:** E Pond Ash Removal

No safety and no environmental issues other than the water leaking through what appears to be a seam in the concrete in E Spillway discharge . Glover started receiving trucks this morning stockpiling stone for the hall road from E pond to D pond around 54 loads today, E pond dewatering pump is up and running again pumping to D pond , Glover is installing a pump in the E pond outfall basin to pump the water back into E pond until the leak can be stopped.

Bruce Howard moving mats out of E Pond and placing around A/B/C ponds.

Fishburn has worked around D pond today.

GAI continuing to direct Bruce Howard and Fishburn.

Crofton arrived on site today looked at water leaks on C pond spillway and E pond spillway with Ruben Williams Supt for Glover and will get back with Ruben on repair and price for E spillway leak.

DOM Carter Cole has been on site with Crofton today.

Leonard "Whitey" C Pope

Dominion Lead

possum point

Cell PH 804-854-3359

Leonard.C [Pope@Dom.Com](mailto:Pope@Dom.Com)